

Ambuja Cements Limited
Unit - Maratha Cement Works
Continuous emission Data for Month of June 2010

Sr.No.	Stack attached to	mg/m3 / Dates ----->																															
		1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30		
1	Limestone Crusher	15	18	21	22	19	21	21	24	28	24	29	27	26	23	20	22	24	26	24	21	20	19	23	29	30	21	24	25	21	20		
2	Rawmill & Kiln exit	We are replacing the existing CEMS with higher version of CEMS. Which is under installation																															
3	Coal Mill B/F	16	5	8	8	13	12	12	12	15	16	15	19	19	20	21	14	10	12	12	13	12	13	13	12	13	13	15	14	4	6		
4	Cooler ESP	25	20	19	21	25	24	24	28	20	17	16	27	26	28	24	24	31	20	24	21	28	21	22	19	21	27	21	21	24	14		
5	Cementmill-1 B/F	10	12	13	4	9	17	16	6	15	14	12	13	16	10	7	9	10	8	12	10	Shutdown					5	12	9	10	7	6	12
6	Cementmill-2 ESP	24	15	19	14	16	12	17	3	7	6	12	7	8	7	6	5	8	6	5	4	5	15	9	7	7	5	7	15	13	9		
7	Cementmill-3 ESP	3	10	3	8	7	5	7	9	6	6	5	7	8	13	17	28	Shutdown					5	10	4	17	18	5	3	10	6	8	13
8	Cementmill-4 B/F	14	3	4	8	7	9	6	4	3	6	8	3	7	4	5	5	9	6	7	5	8	10	12	18	12	11	9	6	9	11		
9	Packer 1	34	30	25	21	28	31	34	25	29	35	29	30	22	29	33	30	28	32	31	33	35	28	32	36	30	29	30	33	31	28		
10	Packer 2	20	27	24	30	21	16	20	22	26	29	31	23	18	15	20	22	17	20	29	24	18	26	29	16	19	26	30	17	15	20		
11	Packer 3	16	19	17	20	22	26	30	20	17	21	26	20	15	19	16	23	18	16	15	25	17	19	20	22	19	16	25	30	32	19		
12	Packer 4	18	16	30	32	20	16	15	23	26	10	12	14	21	25	13	19	20	28	30	20	14	16	21	29	23	19	13	26	29	15		
13	Packer 5	26	30	22	17	19	13	30	21	19	25	20	24	28	19	15	19	24	30	27	35	30	26	32	19	31	23	26	24	20	19		
14	Primary Coal Crusher	26	22	15	18	25	23	20	15	21	26	20	18	24	28	21	19	30	26	20	29	32	17	26	24	29	25	20	17	23	19		
15	Secondary Coal Crusher	22	26	28	20	23	30	33	31	26	24	28	30	17	26	20	24	30	33	38	21	23	29	32	28	22	26	30	21	27	20		
16	CPP Boiler Stack-I	Shutdown					13	20	21	24	26	29	28	26	32	30	25	28	29	27	24	21	30	33	32	23	21	23	27	26	28		
17	CPP Boiler Stack-II	14	18	24	17	19	19	15	9	12	7	3	2	6	21	6	8	17	15	17	16	18	16	10	15	18	10	5	4	11	8		
18	CPP Boiler Stack-III	18	8	31	33	16	2	1	1	10	15	12	18	22	25	20	8	23	19	24	22	21	26	28	13	16	20	15	10	12	18		
19	CPP Boiler Stack-IV	19	28	25	24	20	26	23	20	22	30	24	29	21	24	28	31	Shutdown															

Note : All the values are daily average values

*SP :- System Problem