

## Particulate Matter Value from Continuous Particulate Monitor

**May-10**

Sr. No.	Stack attached to	Particulate Matter in mg/m3 / Dates ----->																															
		1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	
1	Limestone Crusher	Shutdown														24	21	25	28	30	23	29	28	27	26	24	29	27	32	25	26	24	
2	Rawmill & Kiln exit	We are replacing the existing CEMS with higher version of CEMS. Which is under installation stage.																															
3	Coal Mill B/F	Shutdown											21	23	25	24	20	28	25	27	32	24	25	28	27	21	26	23	24	18	21	19	18
4	Cooler ESP	Shutdown						26	27	21	16	15	28	21	25	23	26	32	18	25	26	29	26	24	20	23	27	25	26	32	21	24	
5	Cementmill-1 B/F	19	25	26	28	27	26	28	24	19	20	21	23	24	21	24	20	25	27	26	23	25	28	27	26	23	24	28	29	32	26	24	
6	Cementmill-2 ESP	28	26	28	24	25	16	14	14	14	16	25	24	13	14	13	23	16	14	26	27	29	29	14	13	19	18	12	21	24	21	23	
7	Cementmill-3 ESP	21	19	24	19	20	23	18	19	14	16	19	20	23	21	20	22	23	21	19	24	28	27	26	23	24	26	24	21	26	24	26	
8	Cementmill-4 B/F	24	26	21	25	21	23	24	25	19	20	15	19	27	26	24	25	27	28	29	29	27	28	29	26	24	24	28	26	29	32	21	
9	Packer 1	32	35	26	30	28	25	29	30	26	27	SP	35	28	25	29	30	33	23	28	27	30	27	29	31	28	24	29	33	23	28	32	
10	Packer 2	18	30	23	25	24	20	26	18	16	18	19	18	20	26	24	22	20	21	20	18	18	19	17	20	22	29	24	22	18	20		
11	Packer 3	19	18	16	17	20	16	21	24	18	18	17	16	20	28	25	18	17	16	18	16	15	17	19	18	17	14	20	22	21	20	22	
12	Packer 4	13	19	21	14	15	21	33	25	19	17	24	21	23	16	24	22	21	21	31	21	31	25	28	30	34	32	26	19	26	30	34	
13	Packer 5	24	35	28	20	35	21	18	35	17	18	10	9	18	27	31	26	26	29	37	37	30	31	26	23	18	21	31	26	26	18	17	
14	Primary Coal Crusher	24	26	28	29	19	23	26	27	28	25	26	27	25	24	29	23	25	21	26	24	31	29	27	24	20	15	16	29	28	32	29	
15	Secondary Coal Crusher	23	24	25	21	19	20	27	30	32	31	28	29	26	22	28	23	20	27	30	32	31	28	29	26	22	28	29	21	28	28	26	
16	CPP Boiler Stack-I	Shutdown																															
17	CPP Boiler Stack-II	29	21	24	25	26	28	27	23	32	32	31	29	28	27	26	25	26	29	26	23	19	18	20	16	34	25	26	27	25	26	32	
18	CPP Boiler Stack-III	Shutdown					32	15	19	28	27	26	25	24	23	26	28	27	29	28	26	34	26	25	27	28	26	27	28	29	26	24	
19	CPP Boiler Stack-IV	shutdown							25	26	27	29	28	20	19	23	24	22	21	26	28	25	24	26	27	20	19	18	16	20	24	23	

Note : All the values are daily average values

\*SP :- System Problem